

MODEL				ASH-09BIR					
FUNCTION				FUNCTION					
Cooling	Y		Average season	Y					
Heating	Y		Warmer season	Y					
Design load				Seasonal efficiency					
Item	symbol	value	unit	Item	symbol	value	unit		
Cooling	Pdesignc	2,5	kW	Cooling	SEER	6,1	--		
Heating / Average	Pdesignh	2,6	kW	Heating / Average	SCOP/A	4,0	--		
Heating / Warmer	Pdesignh	2,8	kW	Heating / Warmer	SCOP/W	5,1	--		
Heating / Colder	Pdesignh	2,7	kW	Heating / Colder	SCOP/C	3,2	--		
Declared capacity for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj				Declared energy efficiency ratio, at indoor temperature 27(19)°C and outdoor temperature Tj					
Item	symbol	value	unit	Item	symbol	value	unit		
Tj = 35 °C	Pdc	2,61	kW	Tj = 35 °C	EERd	3,16	--		
Tj = 30 °C	Pdc	1,93	kW	Tj = 30 °C	EERd	4,82	--		
Tj = 25 °C	Pdc	1,20	kW	Tj = 25 °C	EERd	7,85	--		
Tj = 20 °C	Pdc	0,94	kW	Tj = 20 °C	EERd	12,40	--		
Declared capacity for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance / Average season, at indoor temperature 20 °C and outdoor temperature Tj					
Item	symbol	value	unit	Item	symbol	value	unit		
Tj = - 7 °C	Pdh	2,39	kW	Tj = - 7 °C	COPd	2,55	--		
Tj = 2 °C	Pdh	1,42	kW	Tj = 2 °C	COPd	4,18	--		
Tj = 7 °C	Pdh	0,94	kW	Tj = 7 °C	COPd	4,97	--		
Tj = 12 °C	Pdh	0,84	kW	Tj = 12 °C	COPd	5,34	--		
Tj = bivalent temperature	Pdh	2,30	kW	Tj = bivalent temperature	COPd	2,35	--		
Tj = operating limit	Pdh	2,39	kW	Tj = operating limit	COPd	2,55	--		
Declared capacity for heating / Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance / Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					
Item	symbol	value	unit	Item	symbol	value	unit		
Tj = 2 °C	Pdh	2,82	kW	Tj = 2 °C	COPd	2,47	--		
Tj = 7 °C	Pdh	1,84	kW	Tj = 7 °C	COPd	4,92	--		
Tj = 12 °C	Pdh	0,88	kW	Tj = 12 °C	COPd	5,98	--		
Tj = bivalent temperature	Pdh	2,82	kW	Tj = bivalent temperature	COPd	2,47	--		
Tj = operating limit	Pdh	2,82	kW	Tj = operating limit	COPd	2,47	--		
Declared capacity for heating / Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance / Colder season, at indoor temperature 20 °C and outdoor temperature Tj					
Item	symbol	value	unit	Item	symbol	value	unit		
Tj = - 7 °C	Pdh	1,66	kW	Tj = - 7 °C	COPd	2,79	--		
Tj = 2 °C	Pdh	1,00	kW	Tj = 2 °C	COPd	3,77	--		
Tj = 7 °C	Pdh	0,70	kW	Tj = 7 °C	COPd	4,12	--		
Tj = 12 °C	Pdh	0,92	kW	Tj = 12 °C	COPd	5,65	--		
Tj = bivalent temperature	Pdh	2,30	kW	Tj = bivalent temperature	COPd	1,80	--		
Tj = operating limit	Pdh	1,90	kW	Tj = operating limit	COPd	2,54	--		
Tj = - 15 °C	Pdh	2,34	kW	Tj = - 15 °C	COPd	1,97	--		
Bivalent temperature				Operating limit temperature					
Item	symbol	value	unit	Item	symbol	value	unit		
Heating / Average	Tbiv	-7	°C	Heating / Average	Tol	-10	°C		
Heating / Warmer	Tbiv	2	°C	Heating / Warmer	Tol	2	°C		
Heating / Colder	Tbiv	-10	°C	Heating / Colder	Tol	-22	°C		
Cycling interval capacity				Cycling interval efficiency					
Item	symbol	value	unit	Item	symbol	value	unit		
For cooling	Pcycc	x.x	kW	For cooling	EERcyc	x.x	--		
For heating	Pcych	x.x	kW	For heating	COPcyc	x.x	--		
Degradation co-efficient cooling	Cdc	0,25	--	Degradation co-efficient heating	Cdh	0,25	--		
Electric power input in power modes other than 'active mode'				Annual electricity consumption					
Off mode	P _{OFF}	0,00194	kW	Cooling	Q _{CE}	143	kWh/a		
Standby mode	P _{SB}	0,00194	kW	Heating / Average	Q _{HE}	910	kWh/a		
Thermostat-off mode	P _{TO}	0,00394/0,0099	kW	Heating / Warmer	Q _{HE}	769	kWh/a		
Crankcase heater mode	P _{ck}	0,000	kW	Heating / Colder	Q _{HE}	1772	kWh/a		
Capacity control				Other items					
Fixed	N		Sound power level (indoor/outdoor)	L _{WA}	55/60	dB(A)			
Staged	N		Global warming potential	GWP	675	kgCO ₂ eq.			
Variable	Y		Rated air flow (indoor/outdoor)	--	(550/1600)	m ³ / h			
Name and address of the manufacturer or of its authorised representative.				Manufacturer: SINCLAIR Corp. Ltd., 1-4 Argyll St., London, UK					
Contact details for obtaining more information				Representative: SINCLAIR EUROPE spol. s.r.o., Purkyňova 45, 612 00 Brno, CZ					
* R32 (single component refrigerant HFC)				info@sinclair-solutions.com / www.sinclair-solutions.com					
* Device contains fluorinated greenhouse gases covered by the Kyoto Protocol.									